

2017 Street Light Repair Issues

	Date Reported	Issue Description	Address or Location Issue	Repair Performed By	Status/Date	Notes	Staff Comments & Observations (please date stamp comments and observations)
1	10/24/2016	Neutral Fault	10501 Louetta Ln	Edward to repair (Master Services Agreemnt)	completed Jan. 2017	Neutral Fault; repair needed	Neutral Fault- Needs Contractor, 10/27/16 -2nd, 11/3/16-3rd request, 1/24/17
2	3/30/2016	Neutral Fault	Aubrieta Ln. at 153rd Street	Edward to repair (Master Services Agreemnt)	completed	Neutral Fault; repair needed	
3	7/19/2016	Neutral Fault	9041 Sunrise Ln	Edward to repair (Master Services Agreemnt)	completed Jan. 2017	No voltage to pole	Fault, no power at pole as of 8/1/2016 (sb)
4	3/23/2017	Feed relocation required	Orland Woods Drive at Southwest Highway	Edward to repair (Master Services Agreemnt)	completed 5/15/17	Conduit installed outside easement.	Building permit issued for foundation in conflict with existing conduit. Relocation to easement required. (rr)