

Gary Couch

From: Scott Hiland
Sent: Friday, April 08, 2016 2:41 PM
To: Gary Couch
Subject: Fwd: Lazy River Turbine #3 - added parts needed
Attachments: image001.jpg

Sent from my iPhone

Begin forwarded message:

From: Jim Shanley <Jim@illinoispump.com>
Date: April 8, 2016 at 2:04:00 PM CDT
To: Scott Hiland <shiland@orlandpark.org>
Cc: John Deifel <John@illinoispump.com>
Subject: Lazy River Turbine #3 - added parts needed

Scott:

As per my e-mail earlier this week, besides the standard rebuild that we quoted, the pump will also need:

1. New column pipe
2. New casing wear ring
3. Re-machine impeller wear ring to match casing wear ring
4. Re-bore the suction & discharge bowls for new bearings
5. Dip & bake motor windings

The total cost for the above listed material & labor adders is \$3,900.

We need your approval to continue with the rebuild of this pump.

Let me know if you have any questions.

Regards,

James "Big Jim" Shanley

Illinois Pump, Inc.

1801 Winnetka Circle

Rolling Meadows, IL 60008

847-368-PUMP (7867) ext. 1103

fax 847-368-7868

cell 847-875-5339

e-mail jim@illinoispump.com

