

Attachment A.

Village Code Title 5, Chapter 1, Section 13, Item #24.

Section for Variance

24. That Additions and/or Changes to Subsections of 402 for Covered and Open Malls shall read as follows:
- 402.6.2 ITEM #4 MAXIMUM KIOSK AREA:** Kiosks and similar structures shall have a maximum area of 150 square feet.
- EXCEPTION:**
- When a mall is 60 feet or greater width, the maximum area of a kiosk may be increased 100% having a maximum area of 300 square feet in area under the following conditions:
- A. The mall exiting and occupant load design shall comply with Subsections 402.8 “Means of egress” and 402.8.1 “Mall width” of this Chapter.
 - B. A kiosk of more than 150 square feet shall not be placed within the intersecting center spaces of mall corridors (center court).
 - C. A minimum of 15 feet clear exit width to a height of 8 feet shall be provided between any projection of a tenant space bordering the mall and the nearest kiosk, vending machine or similar structure for the adequate means of clear egress travel.
 - D. Kiosks with an area increase shall not be located within 35 feet of an adjacent kiosk or within 48 inches of floor openings for stairways, escalators or guardrails at floor openings.
 - E. Plans submitted with a permit application must include all dimensions for the mall width, kiosk size(s) and the distance between the proposed and nearest existing kiosks and/or other structures.
 - F. Kiosk design must comply with the Illinois Accessibility Code for the public and employees accessibility.

