

From: Travis Parry [mailto:tparry@cbbel.com]
Sent: Friday, June 03, 2011 8:39 AM
To: Frank Stec
Subject: RE: Sportsplex

We did observe quite a bit of sheering at the testing locations. Based on the compressive strength of the concrete, it seemed to us that either a longer or different type of anchor would likely be more effective.

Travis M. Parry, EI, CFM
Water Resources Engineer
Christopher B. Burke Engineering, Ltd.
9575 W. Higgins Road, Suite 600 Rosemont, IL 60018
Phone: (847) 823-0500 Fax: (847) 318-9793
E-Mail: tparry@cbbel.com

The information contained in this e-mail is intended only for the individual or entity to whom it is addressed and should not be opened, read or utilized by any other party. This message shall not be construed as official project information or as direction except as expressly provided in the contract document. Its contents (including any attachments) may contain confidential and/or privileged information. If you are not an intended recipient you must not use, disclose, disseminate, copy or print its contents. If you receive this e-mail in error, please notify the sender by reply e-mail and delete and destroy the message.