



ORLAND FIRE PROTECTION DISTRICT WRITTEN REQUEST FOR RECORDS



Dear Chief (or designee):

Please consider this a request to:

Inspect the following records at the Orland Fire Protection District Administration Office:

Receive copies of the following records from the Orland Fire Protection District:

Fire Report Car Fire Ambulance Report

Hazardous Spills Other _____

Date: 1-13-10 Location: ROBERT DAVIDSON Cottage
14700 Park Lane
(Please be specific in listing records)

I understand that if I request that the records be copied, I will be charged a set fee of \$.15 per page after the first 50 pages, which are at no charge, payable in full when the copies are picked up. All requests for ambulance reports, other than those requested directly by the patient, must include a signed medical release form by the patient. Requests for fire reports must bear the original signature of the insured.

Date: 1-13-10
Name (print): DENNIS WAKURKA
Signature: *Dennis Wakurka*
Address: 14700 PALMVIEW AVE.
708-403-0374
Phone #: CELL 708-562-2364

Orland Fire Protection District Incident Report

FDID CS132 **State** IL
Incident Date 01/11/2010 17:44:31 **Exposure** 0

Location Type 1 Street address
Wildlands **Census Tract**
Address 14700 Park Ln Orland Park IL 60462
Cross Street Highland Ave Orland Park IL
Address Description

Incident Type 111 Building fire
Aid Type N None
Aid Incident Number
Mutual Aid Department [None selected]
Mutual Aid Department State
Incident Begin Time 01/11/2010 17:44:31
Incident End Time 01/11/2010 19:38:27

Action Taken 1 11 Extinguishment by fire service personnel
Action Taken 2
Action Taken 3
Suppression Apparatus Total 2
Suppression Personnel Total 5
EMS Apparatus Total 0
EMS Personnel Total
Other Apparatus Total 0
Other Personnel Total
Property Loss \$10,000.00
Contents Loss \$0.00
Property Value \$0.00
Contents Value \$0.00

Detector Alerted Occupant
Hazmat Released
Mixed Use Property
Property Use 100 Assembly, other

Remarks
 PLASTIC MOP BUCKET NEXT TO FURNACE FOUND IN FLAMES. EXTINGUISHED WITH PUMP CAN. CREWS VENTED BOTH FLOORS. 8151 INVESTIGATING THE CAUSE. BUILDING TURNED OVER TO THE MAINTENANCE MAN AND BUILDING SUPERVISOR

 SMOKE DETECTORS DID NOT ACTIVATE DURING FIRE. PROGRAM COORDINATOR MANUALLY PULLED ALARM WHEN SHE NOTICED SMOKE IN LOWER LEVEL. DENNIS WOKURA FROM VOOP ARRIVED ON SCENE AND ASSISTED

**Orland Fire Protection District
Incident Report**

WITH INFORMATION TBS CLEANING CO LEFT PLASTIC GARBAGE CAN WITH CLEANING SUPPLIES STORED UP AGAINST THE FURNACE UNITS. THE LAST TIME ANYONE WAS IN THE JANITORIAL CLOSET WAS LATE SUNDAY EVENING. THE CAUSE OF THE FIRE WAS RULED COMBUSTIBLES STORED TOO CLOSE TO A HEAT SOURCE. 6151

Officer In Charge ID 6040
Officer In Charge Rank Battalion Chief
Officer In Charge Assignment
Officer Reporting ID 6040
Reporting Officer Rank [None selected]
Reported By Assignment
Reported By Date

**Orland Fire Protection District
Fire Report**

Property Details

No. of Residential Units 0
 No. of Buildings Involved 0
 No. of Acres Burned 0

On-Site Materials or Products

Material 1
 Storage Use 1 N None
 Material 2
 Storage Use 2 N None
 Material 3
 Storage Use 3 N None

Ignition

Area
 62 Heating room or area, water heater area
 Heat Source
 10 Heat from powered equipment, other
 Item First Ignited
 20 Furniture, utensils, other
 Type of material first ignited
 41 Plastic

Cause of Ignition

Exposure Report
 Ignition Cause
 2 Unintentional

Factors of Ignition

00 Other factor contributed to ignition

Human Factors

None
 Asleep
 Possibly Impaired
 by alcohol or
 drugs
 Unattended person
 Mentally disabled
 Physically disabled
 Multiple persons
 Involved
 Age was a factor
 Age 0
 Male Female

Equipment Involved

Equipment Involved
 Power Source
 Brand
 Model
 Serial #
 Year

Fire Suppression Factors

Mobile Property Involved

Type
 Make
 Model
 Year 0
 Plate #
 State
 VIN

**Orland Fire Protection District
Structure Fire Report**

Structure Type	1 Enclosed building
Building Status	2 In normal use
Above Grade Stories	2
Below Grade Stories	1
Main Floor Square Feet	2800
Main Floor Length	70
Main Floor Width	40

Fire Origin Floor	1	Below Grade	<input type="checkbox"/>
Fire Spread	2 Confined to room of origin		
Stories Damaged Minor	0		
Stories Damaged Significa	0		
Stories Damaged Heavy	0		
Stories Damaged Extreme	0		
Fire Spread Material			
Fire Spread Material Type			

Detectors Present	<input type="checkbox"/>
Detector Type	1 Smoke
Detector Power Supply	2 Hardwire only
Detector Operation	3 Detector failed to operate
Detector Effectiveness	
Detector Failure Reason	U Undetermined

AES Present	<input type="checkbox"/>
AES Type	
AES Operation	
AES Sprinkler Heads Work	0
AES Failure Reason	