




PERMIT PLANS
REVIEWED FOR
CODE COMPLIANCE

Permit# BP-20-02636

Date: 6-28-21

Reviewer: [Signature]

Village of Orland Park
Building Division

NOTE:
ILLINOIS ACCESSIBILITY CODE
REQUIRES 5% OF THE SEATING
SHALL BE ACCESSIBLE TO THE
HANDICAP.

NOTE: - "NO WALLS" BEING CONSTRUCTED.

- ONLY NEW ELECTRICAL RECEPTILES
TO POWER GAMING MACHINES
⌘ = RECEPTILES/OUTLETS.

- UTILIZING EXISTING LOUNGE SPACE

- IN SIGHT LINE OF BAR.

NOTE: ALL NEW ELECTRICAL WORK TO BE IN
APPROVED METAL CONDUIT & MIN. #12 COPPER WIRE

