

June 2016 Street Light Repair Issues

	Date Reported	Issue Description	Address or Location Issue	Internal Wk Ord. No.	Pole No	Repair Performed By	Status	Notes	Edward Electric	Rag's Electric	Tri Tech Electric
1	2/25/2016	The light pole has experienced structure failure;	159th St. and 71st Court at the exit of Meijers	14455		4/14/2016 Public Works cut the pole down and brought back to shop	open	Orland Police called to report that the light pole on 71st by the Meijers entrance from 159th Street is failing. Base needs to be relocated. Move concrete base 10' to the north. Double arm, 30 ft. pole needs to be re-installed. Look for police report.	4,600.00	4,410.00	8,973.00
2	3/9/2016	Neutral Fault	140th St & William Drive		74/03	Edward to repair (Master Services Agreeemnt)	open	Neutral Fault; repair needed			
3		No voltage to pole	13336 Firestone Drive			Edward to repair (Master Services Agreeemnt)	open	No voltage to pole			
4	3/17/2016	Knocked down	Orland Parkway & Emile Lane	14784		VOP	open	Pole hit by car. Needs to be reset by a contractor. (light is below high tension wires)	1,570.00	1,100.00	2,581.00
5	4/5/2016	Knocked down	Orland Parkway east of Emile Lane; west of St. Xavier	15158		VOP	open	Contractor repair base damage. Broken anchor bolts in base.	600.00	1,400.00	8,973.00
6		Light control box damaged	9911 143rd Place			VOP	open	Need new box constructed installation by VOP	6,300.00	3,350.00	4,873.00
7	6/18/2016	Pole was hit/ secured wires & cut up pole, brought back to shop	143rd & John Humphrey Drive			VOP	Open	Pole has been secured. Quote in process.	1,740.00	1,400.00	1,525.00
									\$14,810.00	\$11,660.00	\$26,925.00