



VILLAGE OF ORLAND PARK

14700 Ravinia Avenue
Orland Park, IL 60462
www.orland-park.il.us

Department Requested Action

File Number: 2012-0118

Introduced: 2/28/2012

Current Status: PASSED

Version: 1

Matter Type: MOTION

..Title

Reject Bid for Pool & Structure Painting

History

We received 3 bids on February 8, 2012 at 11:00 a.m. for Pool & Structure Painting. After opening the bids it was discovered that there was technical error in the bid specs. The specifications read: "All pool walls, floors, previously coated Chlorinated Rubber to receive SSPC SP 7 brush off blast surfaces." The correct specification should have read: "SSPC SP 13 total removal of all surfaces". It is our recommendation that the bids be rejected and that we re-bid this project with the proper specifications.

Financial Impact

None

Recommended Action/Motion

I move to approve rejecting the current bids and to re-bid the project with new specifications.