

## Gary Couch

---

**From:** Scott Hiland  
**Sent:** Friday, April 08, 2016 2:41 PM  
**To:** Gary Couch  
**Subject:** Fwd: Lazy River Turbine #3 - added parts needed  
**Attachments:** image001.jpg

Sent from my iPhone

Begin forwarded message:

**From:** Jim Shanley <[Jim@illinoispump.com](mailto:Jim@illinoispump.com)>  
**Date:** April 8, 2016 at 2:04:00 PM CDT  
**To:** Scott Hiland <[shiland@orlandpark.org](mailto:shiland@orlandpark.org)>  
**Cc:** John Deifel <[John@illinoispump.com](mailto:John@illinoispump.com)>  
**Subject:** **Lazy River Turbine #3 - added parts needed**

Scott:

As per my e-mail earlier this week, besides the standard rebuild that we quoted, the pump will also need:

1. New column pipe
2. New casing wear ring
3. Re-machine impeller wear ring to match casing wear ring
4. Re-bore the suction & discharge bowls for new bearings
5. Dip & bake motor windings

The total cost for the above listed material & labor adders is \$3,900.

We need your approval to continue with the rebuild of this pump.

Let me know if you have any questions.

Regards,

**James "Big Jim" Shanley**

**Illinois Pump, Inc.**

1801 Winnetka Circle

Rolling Meadows, IL 60008

847-368-PUMP (7867) ext. 1103

fax 847-368-7868

cell 847-875-5339

e-mail [jim@illinoispump.com](mailto:jim@illinoispump.com)

